



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Notified Body 1020

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1020 – CPR – 010032723

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF)

EN 14304:2009+A1:2013

types: listed in annex no. 1

placed on the market under the name or trade mark of

ODE YALITIM SANAYİ VE TİCARET A.Ş.

Piyale Paşa Bulvarı Ortadoğu Plaza K-12 34384 Okmeydanı - Şişli/ İSTANBUL / TURKEY

and produced in the manufacturing plant:

Plant 1

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14304:2009+A1:2013

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the


constancy of performance of the construction product.

This certificate was first issued on 27.1.2014 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The stamp of the Notified Body 1020

Prague, 14th December, 2018




Ing. Iveta Jiroutová
Deputy manager of the Notified Body



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Annex no. 1
Certificate no. 1020-CPR-010032723

Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF) EN 14304:2009+A1:2013 products

Types: ODE R-FLEX:

ODE R-FLEX PRM BORU/ HVAC Insulation PIPE

ODE R-FLEX STD BORU/ HVAC Insulation PIPE

ODE R-FLEX PRM LEVHA/ HVAC Insulation ROLL

ODE R-FLEX STD LEVHA/ HVAC Insulation ROLL

ODE R-FLEX PRM BORU/HVAC INSULATION PIPE

Length: 2000 mm

Wall thicknesses: 6 mm - 32 mm

Inside diameter: 6 mm - 114 mm

ODE R-FLEX STD BORU/HVAC INSULATION PIPE

Length: 2000 mm

Wall thicknesses: 6 mm - 32 mm

Inside diameter: 6 mm - 114 mm

ODE R-FLEX PRM LEVHA/HVAC INSULATION ROLL

Width: 1000 mm

Thicknesses: 6 mm - 50 mm

Length: 5000 mm – 15000 mm

ODE R-FLEX STD LEVHA/HVAC INSULATION ROLL

Width: 1000 mm


Thicknesses: 6 mm - 40 mm

Length: 7000 mm – 15000 mm

The stamp of the Notified Body 1020

Prague, 14th December, 2018




Ing. Iveta Jiroutova
Deputy manager of the Notified Body