

Bitufa Waterproofing B.V.
t.a.v. de heer D. Rouwenhorst
Vlijtweg 4
8191 JP WAPENVELD

Date
25 juli 2013

Your reference
-

Our reference
DK490066/B20131093B/marco_dekok

Regarding
The need for CE-arking of Flexobit (non-reinforced bituminous sheet).

Dear Mr. Rouwenhorst,

With this letter we confirm the following.

The product Flexobit, which is a non-reinforced bituminous sheet, is not part of the scope of the following standards:

- NEN-EN 13707: Flexible sheets for waterproofing – Reinforced bitumen sheets for roof waterproofing – Definitions and characteristics
- NEN-EN 13969: Flexible sheets for waterproofing – Bitumen damp proof sheets including bitumen basement tanking sheets – Definitions and characteristics
- NEN-EN 13970: Flexible sheets for waterproofing – Bitumen water vapour control layers – Definitions and characteristics
- NEN-EN 14695: Flexible sheets for waterproofing – Reinforced bitumen sheets for roof waterproofing of concrete bridge decks and other concrete surfaces trafficable by vehicles – Definitions and characteristics

The reason for Flexobit not being part of the scope of the above listed standards is that the scope of these standards is covering only reinforced sheets. Since Flexobit is a non-reinforced sheet, this product is not part of the scope of any of these standards.

This is the reason why CE-marking of the product Flexobit is not possible.

Best regards,


Marco de Kok
Accountmanager